

### Seasonal Home

West Falmouth, MA  
General Certificate  
(Pressure Dosed System)

		TN (influent)	NO2	NO3	TKN	TN (effluent)	Removal Rate
1	August 23, 2006	90.2	BRL	BRL	17.1	17.1	81.0%
2	October 20, 2006	118.0	0.68	1.08	8.4	10.2	91.4%
3	August 24, 2007	107.0	BRL	BRL	17.9	17.9	83.3%
4	October 4, 2007	122.0	BRL	1.55	3.92	5.5	95.5%
5	July 9, 2008	77.3	BRL	BRL	20	20.0	74.1%
6	August 12, 2008	---	0.49	0.76	5.5	6.7	---
7	September 19, 2008	69.0	BRL	BRL	5.6	5.6	91.9%
8	July 16, 2009	68.3	0.19	5.62	11.3	17.1	75.0%
9	September 10, 2009	85.0	BRL	BRL	17.4	17.4	79.5%
10	July 14, 2010	---	0.02	0.05	11.5	11.6	---
11	September 15, 2010	---	0.02	0.32	10.9	11.2	---

**TN Average**

**12.8 mg/l**

