

Year Round Home

Plainville, MA
General Certificate
(Gravity System)

		TN (influent)	NO2	NO3	TKN	TN (effluent)	Removal Rate
1	November 5, 2007	57.3	5.1	7.90	BRL	13.00	77.3%
2	February 14, 2008	58.0	BRL	2.90	8.40	11.30	80.5%
3	May 14, 2008	70.6	BRL	BRL	7.30	7.30	89.7%
4	August 20, 2008	47.9	BRL	BRL	8.40	8.40	82.5%
5	December 11, 2008	---	2.35	2.89	2.94	8.18	---
6	February 19, 2009	---	BRL	BRL	12.30	12.30	---
7	May 14, 2009	---	BRL	1.84	5.74	7.58	---
8	August 6, 2009	---	BRL	14.5	3.36	17.86	---
9	November 9, 2009	---	2.7	11.2	4.20	18.10	---
10	September 16, 2010	---	0.02	9.53	7.00	16.55	---

TN Average

12.1 mg/l

